

元智大學環科中心檢測實驗室

樣品檢驗報告

委 託 單 位：御安淨水企業有限公司

委託編號：YZ1101C1719

委託者地址：桃園市平鎮區中豐路南勢二段127號

樣品基質：飲用水

受 檢 單 位：家興人力資源顧問股份有限公司

檢測目的：定檢

行 業 別 : 自述業別

採樣時間：110年05月23日13時00分

採樣地點：新化中正館 08/辦公室飲水機

收樣時間：110年05月24日

(台南市新化區)

採樣單位：御安淨水企業有限公司

報告日期：110年05月28日

採樣方法：---

報告編號：C1101719-1

採樣行程代碼： ---

[illegible]



Accreditation number by EPA : 041

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd

Client Number: YZ1101C1719

Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

Sample Base: Drinking Water

Plant: Golden Li H.R Consultant Co., Ltd

Test purpose: Regular inspection

IndustrialType: ---

Sampling Date: 05/23/2021 13:00

Sampling Site: Xinhua Zhongzheng Pavilion 08/Office water dispenser

Sample Received: 05/24/2021

Sampling Organization: Yuann International Technology Co., Ltd

Report Date: 05/28/2021

Sampling Method: ---

Report Number: C1101719-1

Sampling Code: ---

Sample Report Number		C1100524AG				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/24/2021 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
				</				

PASS