行政院環保署認可證字號：041

# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1101C2037
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：110年06月22日15時50分
採樣地點：湖口興華館C10飲水機　　收樣時間：110年06月23日
(新竹縣湖口鄉　　)
採樣單位：御安淨水企業有限公司　　報告日期：110年06月25日
採樣方法：---　　報告編號：C1102037-1
採樣行程代碼：---

| 樣品報告編號 | | C1100623F | | | | 檢驗方法 | 環保署飲用水標準值 | 備註欄 |
|---|---|---|---|---|---|---|---|---|
| 原樣名稱或編號 | | 飲用水 | | | | | | |
| 檢測項目 | 單位 | 檢測值 | 開始培養時間 | 培養基名稱 | 原始數據 | | | |
| 大腸桿菌群 | CFU/100 mL | <1 | 110年06月23日 12時00分 | LES Endo Agar | 1倍/0，0 | NIEA E230.55B | 6 | |
| 以下空白 | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

PASS



檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

Accreditation number by EPA：041

# Environmental Technology Research Center
# YUAN ZE UNIVERSITY
## Analysis Report

**Client:** Yuann International Technology Co., Ltd
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
**Plant:** Golden Li H.R Consultant Co., Ltd
**IndustrialType:** ---
**Sampling Site:** Hukou Xinghua Hall C10 drinking fountain

**Client Number:** YZ1101C2037
**Sample Base:** Drinking Water
**Test purpose:** **Regular inspection**
**Sampling Date:** 06/22/2021 15:50
**Sample Received:** 06/23/2021

**Sampling Organization:** Yuann International Technology Co., Ltd
**Sampling Method:** ---
**Sampling Code:** ---

**Report Date:** 06/25/2021
**Report Number:** C1102037-1

| Sample Report Number | | C1100623F | | | | Analytical Method | Drinking water standard of EPA | Remarks |
|---|---|---|---|---|---|---|---|---|
| Sample Name(Number) | | Drinking Water | | | | | | |
| Analyzed Item | Unit | Analytical Value | Start Time of Incubating | Medium | Original Data | | | |
| Coliform Group | CFU/100 mL | <1 | 06/23/2021 12:00 | LES Endo Agar | 1/0，0 | NIEA E230.55B | 6 | |
| **The END** | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

PASS



Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887