



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段127號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：新豐中崙一館D1飲水機
 (新竹縣新豐鄉)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1111C1988
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：111年06月07日14時00分
 收樣時間：111年06月08日
 報告日期：111年06月13日
 報告編號：C1111988-1

樣品報告編號		C1110608C				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	111年06月08日 12時00分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
以下空白								
		PASS						



元智大學環科中心檢測實驗室

樣品檢驗報告

委 託 單 位：御安淨水企業有限公司

委託編號：YZ1111C1988

委託者地址：桃園市平鎮區中豐路南勢二段127號

樣品基質：飲用水

受 檢 單 位：家興人力資源顧問股份有限公司

檢測目的：定檢

行 業 別 : 自述業別

採樣時間：111年06月07日14時05分

採樣地點：新豐中崙一館 D2 飲水機

收樣時間：111年06月08日

(新竹縣新豐鄉)

採樣單位：御安淨水企業有限公司

報告日期：111年06月13日

採樣方法：---

報告編號：C1111988-2

採樣行程代碼：---

[illegible]

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Xinfeng Zhonglun 1 dormitory / D2 drinking fountain

Client Number: YZ1111C1988
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 06/07/2022 14:05
Sample Received: 06/08/2022

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 06/13/2022
Report Number: C1111988-2

[illegible]