




元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1111C2926
委託者地址：桃園市平鎮區中豐路南勢二段127號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：111年08月03日19時30分
採樣地點：大園三民一館1F飲水機 (桃園市大園區)	收樣時間：111年08月04日
採樣單位：御安淨水企業有限公司	報告日期：111年08月08日
採樣方法：---	報告編號：C1112926-1
採樣行程代碼：---	

樣品報告編號		C1110804M				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	111年08月04日 18時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								
								



Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Dayuan Sanminyi Hall 1,1F Water Dispenser

Client Number: YZ1111C2926
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 08/03/2022 19:30
Sample Received: 08/04/2022

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 08/08/2022
Report Number: C1112926-1

Table with 9 columns: Sample Report Number, Sample Name(Number), Analyzed Item, Unit, Analytical Value, Start Time of Incubating, Medium, Original Data, Analytical Method, Drinking water standard of EPA, Remarks. Includes a 'PASS' stamp and 'The END' text.