

Report no. : NAD2280058102

Page no.: 1 OF 1

Date reported : Aug. 12, 2022

The following test was submitted & identified by the client as:

Client name : Summit Manpower Agency Co., Ltd.

Matrix: Water sample

Sample no. : NAD22800581001

Sampling by : SGS Taiwan Ltd.

Sampling method : NIEA W101.56A

Analytical purpose : Periodic monitoring

Sampling location :

Sampled date: Aug. 05, 2022 13:00

Received date: Aug. 05, 2022 17:10

Test Results :

Test Requested	Test Result (Unit)	Test Method	Drinking Water Quality Standard
Coliform Group	<1 (CFU/100mL)	NIEA E230.55B	6 (CFU/100mL)

- Remarks:
- 1.This test document cannot be reproduced in any way, except in full content, without the prior approval in writing of the laboratory.
 - 2.The results shown in this test report refer only to the sample(s) tested unless otherwise stated.
 - 3.If there are any discrepancy, the Mandarin version shall prevail.
 - 4.When the amount of colony forms above 100, the test result is shown in scientific notation. (Example: 1.5×10^2 is written as 1.5E+02)



Pannu Liu / Manager-Tech.
SIGNED FOR AND ON BEHALF OF
SGS TAIWAN LTD.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.