行政院環保署認可證字號：041

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1111C4156
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：111年11月03日12時20分
採樣地點：大園三民二館9F飲水機　　收樣時間：111年11月04日
(桃園市大園區　　)
採樣單位：御安淨水企業有限公司　　報告日期：111年11月14日
採樣方法：---　　報告編號：C1114156-1
採樣行程代碼：---

樣品報告編號		C1111104B				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	111年11月04日 11時30分	LES Endo Agar	1倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

Accreditation number by EPA：041

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Dayuan Sanminyi Hall 2,9F Water Dispenser

Client Number: YZ1111C4156
Sample Base: Drinking Water
Test purpose: **Regular inspection**
Sampling Date: 11/03/2022 12:20
Sample Received: 11/04/2022

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 11/14/2022
Report Number: C1114156-1

Sample Report Number		C1111104B				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/04/2022 11:30	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								
		PASS						

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887