



# 元智大學環科中心檢測實驗室 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：錄興國際股份有限公司  
 行業別：自述業別  
 採樣地點：中壢中華二館 A01 飲水機  
 (桃園市中壢區)

委託編號：YZ1121C0791  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：112年03月01日14時00分  
 收樣時間：112年03月02日

採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

報告日期：112年03月06日  
 報告編號：C1120791-1

樣品報告編號		C1120302A				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	112年03月02日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



Accreditation number by EPA : 041

# Environmental Technology Research Center YUAN ZE UNIVERSITY

## Analysis Report

**Client:** Yuann International Technology Co., Ltd      **Client Number:** YZ1121C0791  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)      **Sample Base:** Drinking Water  
**Plant:** Golden -Brother International Co., Ltd.      **Test purpose:** Regular inspection  
**IndustrialType:** ---      **Sampling Date:** 03/01/2023 14:00  
**Sampling Site:** Zhongli Zhonghua 2nd building A01 Drinking fountain      **Sample Received:** 03/02/2023

**Sampling Organization:** Yuann International Technology Co., Ltd      **Report Date:** 03/06/2023  
**Sampling Method:** ---      **Report Number:** C1120791-1  
**Sampling Code:** ---

Sample Report Number		C1120302A				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/02/2023 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**