



元智大學環科中心檢測實驗室 樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段127號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：蘆竹長興一館3F飲水機
 (桃園市蘆竹區)

委託編號：YZ1121C1121
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：112年03月21日15時00分
 收樣時間：112年03月22日

採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

報告日期：112年03月27日
 報告編號：C1121121-1

樣品報告編號		C1120322B				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	112年03月22日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								



Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Luzhu Changsing Hall 1 3F drinking fountain

Client Number: YZ1121C1121
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 03/21/2023 15:00
Sample Received: 03/22/2023

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 03/27/2023
Report Number: C1121121-1

Sample Report Number		C1120322B				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/22/2023 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								

PASS