



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1121C1331
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：鎩興國際股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：112年04月11日16時00分
採樣地點：中壢文化一館 A6/3F 飲水機 (桃園市中壢區)	收樣時間：112年04月12日
採樣單位：御安淨水企業有限公司	報告日期：112年04月19日
採樣方法：---	報告編號：C1121331-1
採樣行程代碼：---	

樣品報告編號		C1120412H				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	112年04月12日 12時00分	LES Endo Agar	1倍/0.0	NIEA E230.55B	6	
以下空白								



Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden -Brother International Co., Ltd.
IndustrialType: ---
Sampling Site: Zhongli Wenhua 1st building A6/3F water dispenser

Client Number: YZ1121C1331
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 04/11/2023 16:00
Sample Received: 04/12/2023

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 04/19/2023
Report Number: C1121331-1

Table with columns: Sample Report Number, Sample Name(Number), Analyzed Item, Unit, Analytical Value, Start Time of Incubating, Medium, Original Data, Analytical Method, Drinking water standard of EPA, Remarks. Includes a 'PASS' stamp and 'The END' text.