



元智大學環科中心檢測實驗室

樣品檢驗報告

<p>委託單位：御安淨水企業有限公司 委託者地址：桃園市平鎮區中豐路南勢二段127號 受檢單位：錄興國際股份有限公司 行業別：自述業別 採樣地點：中壢吉林三館 J01/4F 飲水機 (桃園市中壢區)</p>	<p>委託編號：YZ1121C3288 樣品基質：飲用水 檢測目的：定檢 採樣時間：112年08月14日 13時30分 收樣時間：112年08月15日 報告日期：112年08月23日 報告編號：C1123288-1</p>
<p>採樣單位：御安淨水企業有限公司 採樣方法：--- 採樣行程代碼：---</p>	

樣品報告編號		C1120815B				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	112年08月15日 12時00分	LES Endo Agar	1倍/0,0	NIEA E230.55B	6	
以下空白								
<div style="border: 2px solid blue; padding: 5px; display: inline-block; font-size: 2em; font-weight: bold; color: blue;">PASS</div>								



Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden -Brother International Co., Ltd.
IndustrialType: ---
Sampling Site: Zhongli Jilin 3rd building J01/4F water dispenser

Client Number: YZ1121C3288
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 08/14/2023 13:30
Sample Received: 08/15/2023

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 08/23/2023
Report Number: C1123288-1

Sample Report Number		C1120815B				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	08/15/2023 12:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								
PASS								