



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1121C3989
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：112年10月03日15時30分
採樣地點：香山富群二館 6F-A 飲水機 (新竹市香山區)	收樣時間：112年10月04日
採樣單位：御安淨水企業有限公司	報告日期：112年10月13日
採樣方法：---	報告編號：C1123989-1
採樣行程代碼：---	

樣品報告編號		C1121004C				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	112年10月04日 12時00分	LES Endo Agar	1倍/0.0	NIEA E230.55B	6	
以下空白								



國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：	御安淨水企業有限公司	委託編號：	YZ1121C3989
委託者地址：	桃園市平鎮區中豐路南勢二段 127 號	樣品基質：	飲用水
受檢單位：	家興人力資源顧問股份有限公司	檢測目的：	定檢
行業別：	自述業別	採樣時間：	112年10月03日15時35分
採樣地點：	香山富群二館 6F-B 飲水機 (新竹市香山區)	收樣時間：	112年10月04日
採樣單位：	御安淨水企業有限公司	報告日期：	112年10月13日
採樣方法：	---	報告編號：	C1123989-2
採樣行程代碼：	---		

樣品報告編號		C1121004D				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	112年10月04日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								
		PASS						



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd

Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan
 County, Taiwan (R.O.C.)

Plant: Golden Li H.R Consultant Co., Ltd

IndustrialType: ---

Sampling Site: Xiangshan Fuqun Building 2 ,6F-A Water Dispenser

Sampling Organization: Yuann International Technology Co., Ltd

Sampling Method: ---

Sampling Code: ---

Client Number: YZ1121C3989

Sample Base: Drinking Water

Test purpose: Regular inspection

Sampling Date: 10/03/2023 15:30

Sample Received: 10/04/2023

Report Date: 10/13/2023

Report Number: C1123989-1

Sample Report Number		C1121004C				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	10/04/2023 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
			PASS					



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd	Client Number: YZ1121C3989
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)	Sample Base: Drinking Water
Plant: Golden Li H.R Consultant Co., Ltd	Test purpose: Regular inspection
IndustrialType: ---	Sampling Date: 10/03/2023 15:35
Sampling Site: Xiangshan Fuqun Building 2, 6F-B Water Dispenser	Sample Received: 10/04/2023
Sampling Organization: Yuann International Technology Co., Ltd	Report Date: 10/13/2023
Sampling Method: ---	Report Number: C1123989-2
Sampling Code: ---	

Sample Report Number		C1121004D				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	10/04/2023 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
			PASS					