

聯絡人：林愛苹

報生車庫章
登載不實為造文書及貪污治罪條例
台灣檢驗科技股份有限公司
高雄分公司環境實驗室-高雄
負責人：曾偉明
貴人：劉士萍
負貴人：劉士萍
檢貴人：劉士萍
驗貴人：劉士萍
室貴人：劉士萍
主貴人：劉士萍
管貴人：劉士萍

頁次(1/1)

Analytical Report

Report no.: NAD23A00734002

Page no.: 1 OF 1

Date reported: Oct. 23, 2023

Description:

Testee : Summit Manpower Agency Co., Ltd.

Matrix : Water sample

Sample no. : NAD23A00734001

Sampled by : SGS Taiwan Ltd.-Kaohsiung

Sampling method : NIEA W101.56A

Sampling location :

Analytical purpose : Periodic monitoring

Sampled date : Oct. 17, 2023 13:20

Received date : Oct. 17, 2023 18:10

Test Results :

Sample Details	Coliform Group Test Results (Unit) NIEA E230.55B	Remark
Drinking Water Standards	6 (CFU/100mL)	
NAD23A00734001 (2F)	<1 (CFU/100mL)	

- Remarks: 1. This test report is only responsible for supplied sample(s). Any partial copy or use of advertisement will not be permitted.
2. Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested.
3. If there are any discrepancy, the Mandarin version shall prevail.
4. When the colony-forming unit is greater than 100, the data is indicated with scientific notation. For example, 1.5E+02 is indicated as 1.5×10^2 .



Elvis Chang /Asst. Supervisor
SIGNED FOR AND ON BEHALF OF
SGS TAIWAN LTD.