



國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1131C1021
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：113年03月11日09時30分
採樣地點：龜山文華館 C02/2F 飲水機 (桃園市龜山區)	收樣時間：113年03月11日
採樣單位：御安淨水企業有限公司	報告日期：113年03月19日
採樣方法：---	報告編號：C1131021-1
採樣行程代碼：---	

樣品報告編號		C1130311E				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年03月11日 18時00分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
以下空白								
		PASS						



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1131C1021
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：113年03月11日09時35分
採樣地點：龜山文華館 C09/2F 飲水機 (桃園市龜山區)	收樣時間：113年03月11日
採樣單位：御安淨水企業有限公司	報告日期：113年03月19日
採樣方法：---	報告編號：C1131021-2
採樣行程代碼：---	

樣品報告編號		C1130311F				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年03月11日 18時00分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
以下空白								
PASS								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：龜山文華館 C10/2F 飲水機
 (桃園市龜山區)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C1021
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年03月11日09時40分
 收樣時間：113年03月11日
 報告日期：113年03月19日
 報告編號：C1131021-3

樣品報告編號		C1130311G				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年03月11日 18時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：龜山文華館 C11/2F 飲水機
 (桃園市龜山區)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C1021
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年03月11日09時45分
 收樣時間：113年03月11日
 報告日期：113年03月19日
 報告編號：C1131021-4

樣品報告編號		C1130311H				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年03月11日 18時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1131C1021
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：113年03月11日09時50分
採樣地點：龜山文華館 C12/2F 飲水機 (桃園市龜山區)	收樣時間：113年03月11日
採樣單位：御安淨水企業有限公司	報告日期：113年03月19日
採樣方法：---	報告編號：C1131021-5
採樣行程代碼：---	

樣品報告編號		C1130311I				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年03月11日 18時00分	LES Endo Agar	1倍/0,0	NIEA E230.55B	6	
以下空白								
								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1131C1021
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：113年03月11日09時55分
採樣地點：龜山文華館 C13/2F 飲水機 (桃園市龜山區)	收樣時間：113年03月11日
採樣單位：御安淨水企業有限公司	報告日期：113年03月19日
採樣方法：---	報告編號：C1131021-6
採樣行程代碼：---	

樣品報告編號		C1130311J				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年03月11日 18時00分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
以下空白								
PASS								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：龜山文華館 C14/1F 飲水機
 (桃園市龜山區)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C1021
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年03月11日10時00分
 收樣時間：113年03月11日
 報告日期：113年03月19日
 報告編號：C1131021-7

樣品報告編號		C1130311K				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年03月11日 18時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C1021
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號 樣品基質：飲用水
 受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
 行業別：自述業別 採樣時間：113年03月11日10時05分
 採樣地點：龜山文華館 C15/1F 飲水機 收樣時間：113年03月11日
 (桃園市龜山區))
 採樣單位：御安淨水企業有限公司 報告日期：113年03月19日
 採樣方法：--- 報告編號：C1131021-8
 採樣行程代碼：---

樣品報告編號		C1130311L				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年03月11日 18時00分	LES Endo Agar	1倍/0,0	NIEA E230.55B	6	
[以下空白]								
								



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center YUAN ZE UNIVERSITY Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Lucky dorm C02/2F drinking fountain

Client Number: YZ1131C1021
Sample Base: Drinking Water

Regular inspection

Sampling Date: 03/11/2024 09:30
Sample Received: 03/11/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 03/19/2024
Report Number: C1131021-1

Sample Report Number		C1130311E				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/11/2024 18:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
PASS								



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Lucky dorm C09/2F drinking fountain

Client Number: YZ1131C1021
Sample Base: Drinking Water

Regular inspection
Sampling Date: 03/11/2024 09:35
Sample Received: 03/11/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 03/19/2024
Report Number: C1131021-2

Sample Report Number		C1130311F				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/11/2024 18:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
PASS								



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Lucky dorm C10/2F drinking fountain

Client Number: YZ1131C1021
Sample Base: Drinking Water
Regular inspection
Sampling Date: 03/11/2024 09:40
Sample Received: 03/11/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---
Report Date: 03/19/2024
Report Number: C1131021-3

Sample Report Number		C1130311G				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/11/2024 18:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								
			PASS					



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan
 County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Lucky dorm C11/2F drinking fountain

Client Number: YZ1131C1021
Sample Base: Drinking Water

Regular inspection

Sampling Date: 03/11/2024 09:45
Sample Received: 03/11/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 03/19/2024
Report Number: C1131021-4

Sample Report Number		C1130311H				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/11/2024 18:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								

PASS



Accreditation number by NERA : 041
(original Accreditation number by EPA : 041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Lucky dorm C12/2F drinking fountain

Client Number: YZ1131C1021
Sample Base: Drinking Water
Regular inspection
Sampling Date: 03/11/2024 09:50
Sample Received: 03/11/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---
Report Date: 03/19/2024
Report Number: C1131021-5

Sample Report Number		C1130311I				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/11/2024 18:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
		PASS						



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center

YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Lucky dorm C13/2F drinking fountain

Client Number: YZ1131C1021
Sample Base: Drinking Water

Regular inspection

Sampling Date: 03/11/2024 09:55
Sample Received: 03/11/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 03/19/2024
Report Number: C1131021-6

Sample Report Number		C1130311J				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/11/2024 18:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								

PASS



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Lucky dorm C14/1F drinking fountain

Client Number: YZ1131C1021
Sample Base: Drinking Water

Regular inspection
Sampling Date: 03/11/2024 10:00
Sample Received: 03/11/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 03/19/2024
Report Number: C1131021-7

Sample Report Number		C1130311K				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/11/2024 18:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								

PASS



Accreditation number by NERA : 041
(original Accreditation number by EPA : 041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan
County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Lucky dorm C15/1F drinking fountain

Client Number: YZ1131C1021
Sample Base: Drinking Water

Regular inspection

Sampling Date: 03/11/2024 10:05
Sample Received: 03/11/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 03/19/2024
Report Number: C1131021-8

Sample Report Number		C1130311L				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/11/2024 18:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
PASS								