國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時00分
採樣地點：高雄大學館 338 號 H01/10F　　收樣時間：113年05月09日
(高雄市楠梓區　　)
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-1
採樣行程代碼：---

樣品報告編號		C1130509C				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時05分
採樣地點：高雄大學館 338 號 H02/4F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-2
採樣行程代碼：---

樣品報告編號		C1130509D				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時10分
採樣地點：高雄大學館 336 號 H03/4F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-3
採樣行程代碼：---

樣品報告編號		C1130509E				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時15分
採樣地點：高雄大學館 338 號 H04/1F (高雄市楠梓區　)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-4
採樣行程代碼：---

樣品報告編號		C1130509F				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時20分
採樣地點：高雄大學館 338 號 H05/1F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-5
採樣行程代碼：---

樣品報告編號		C1130509G				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時25分
採樣地點：高雄大學館 H06/B 棟 7F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-6
採樣行程代碼：---

樣品報告編號		C1130509H				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時30分
採樣地點：高雄大學館 H07/A 棟 7F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-7
採樣行程代碼：---

樣品報告編號		C1130509I				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時35分
採樣地點：高雄大學館 H08/A 棟 10F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-8
採樣行程代碼：---

樣品報告編號		C1130509J				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時40分
採樣地點：高雄大學館 H09/1F 飲水機 (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-9
採樣行程代碼：---

樣品報告編號		C1130509K				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時45分
採樣地點：高雄大學館 H10/12F 飲水機　　收樣時間：113年05月09日
(高雄市楠梓區　　)
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-10
採樣行程代碼：---

樣品報告編號		C1130509L				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時50分
採樣地點：高雄大學館 H11/12F 飲水機 (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-11
採樣行程代碼：---

樣品報告編號		C1130509M				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年05月09日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時00分
採樣地點：高雄大學館338號H01/10F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-12
採樣行程代碼：---

樣品報告編號		C1130509C				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時05分
採樣地點：高雄大學館338號H02/4F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-13
採樣行程代碼：---

樣品報告編號		C1130509D				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時10分
採樣地點：高雄大學館336號H03/4F　　收樣時間：113年05月09日
(高雄市楠梓區　　)
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-14
採樣行程代碼：---

樣品報告編號		C1130509E				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時15分
採樣地點：高雄大學館338號H04/1F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-15
採樣行程代碼：---

樣品報告編號		C1130509F				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時20分
採樣地點：高雄大學館338號H05/1F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-16
採樣行程代碼：---

樣品報告編號		C1130509G				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時25分
採樣地點：高雄大學館H06/B棟7F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-17
採樣行程代碼：---

樣品報告編號		C1130509H				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時30分
採樣地點：高雄大學館H07/A棟7F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-18
採樣行程代碼：---

樣品報告編號		C1130509I				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時35分
採樣地點：高雄大學館H08/A棟10F (高雄市楠梓區)　　收樣時間：113年05月09日
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-19
採樣行程代碼：---

樣品報告編號		C1130509J				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日 12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時40分
採樣地點：高雄大學館H09/1F飲水機　　收樣時間：113年05月09日
(高雄市楠梓區　　)
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-20
採樣行程代碼：---

樣品報告編號		C1130509K				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時45分
採樣地點：高雄大學館H10/12F飲水機　　收樣時間：113年05月09日
(高雄市楠梓區　　)
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-21
採樣行程代碼：---

樣品報告編號		C1130509L				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1131C2072
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：113年05月08日14時50分
採樣地點：高雄大學館H11/12F飲水機　　收樣時間：113年05月09日
(高雄市楠梓區　　)
採樣單位：御安淨水企業有限公司　　報告日期：113年05月20日
採樣方法：---　　報告編號：C1132072-22
採樣行程代碼：---

樣品報告編號		C1130509M				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年05月09日 12時00分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　傳真：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H01/ 10F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:00
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-1

Sample Report Number		C1130509C				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H02/ 4F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:05
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-2

Sample Report Number		C1130509D				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.336 H03/ 4F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:10
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-3

Sample Report Number		C1130509E				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H04/ 1F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:15
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-4

Sample Report Number		C1130509F				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H05/ 1F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:20
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-5

Sample Report Number		C1130509G				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H06/ Building B 7F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:25
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-6

Sample Report Number		C1130509H				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H07 /Building A 7F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:30
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-7

Sample Report Number		C1130509I				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H08 /Building A 10F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:35
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-8

Sample Report Number		C1130509J				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H09/ 1F water dispenser

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:40
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-9

Sample Report Number		C1130509K				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H10/ 12F water dispenser

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:45
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-10

Sample Report Number		C1130509L				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H11/ 12F water dispenser

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:50
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-11

Sample Report Number		C1130509M				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/09/2024 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H01/ 10F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:00
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-12

Sample Report Number		C1130509C				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H02/ 4F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:05
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-13

Sample Report Number		C1130509D				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.336 H03/ 4F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:10
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-14

Sample Report Number		C1130509E				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H04/ 1F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:15
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-15

Sample Report Number		C1130509F				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H05/ 1F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:20
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-16

Sample Report Number		C1130509G				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H06/ Building B 7F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:25
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-17

Sample Report Number		C1130509H				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H07 /Building A 7F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:30
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-18

Sample Report Number		C1130509I				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H08 /Building A 10F

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:35
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-19

Sample Report Number		C1130509J				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H09/ 1F water dispenser

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:40
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-20

Sample Report Number		C1130509K				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H10/ 12F water dispenser

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:45
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-21

Sample Report Number		C1130509L				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H11/ 12F water dispenser

Client Number: YZ1131C2072
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/08/2024 14:50
Sample Received: 05/09/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/20/2024
Report Number: C1132072-22

Sample Report Number		C1130509M				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	05/09/2024 12:00	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887