



國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：錄興國際股份有限公司
 行業別：自述業別
 採樣地點：中壢中華二館 A05 飲水機
 (桃園市中壢區)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4826
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月04日11時00分
 收樣時間：113年11月05日
 報告日期：113年11月18日
 報告編號：C1134826-1

樣品報告編號		C1131105A				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月05日 10時30分	LES Endo Agar	1倍/0.0	NIEA E230.55B	6	
以下空白								

PASS



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden –Brother International Co., Ltd.
IndustrialType: ---
Sampling Site: Zhongli Zhonghua 2nd building A05 Drinking fountain

Client Number: YZ1131C4826
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/04/2024 11:00
Sample Received: 11/05/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---
Report Date: 11/18/2024
Report Number: C1134826-1

Sample Report Number		C1131105A				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/05/2024 10:30	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								

PASS