國環檢證字號：041(原環署環檢字第 041 號)

# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司
委託者地址：桃園市平鎮區中豐路南勢二段 127 號
受檢單位：鎵興國際股份有限公司
行業別：自述業別
採樣地點：中壢文化二館 H1/1F 飲水機 (桃園市中壢區 )
採樣單位：御安淨水企業有限公司
採樣方法：---
採樣行程代碼：---

委託編號：YZ1141C4753
樣品基質：飲用水
檢測目的：定檢
採樣時間：114年11月03日15時40分
收樣時間：114年11月04日
報告日期：114年11月17日
報告編號：C1144753-1

| 樣品報告編號 | | C1141104K | | | | 檢驗方法 | 環境部飲用水標準值 | 備註欄 |
|---|---|---|---|---|---|---|---|---|
| 原樣名稱或編號 | | 飲用水 | | | | | | |
| 檢測項目 | 單位 | 檢測值 | 開始培養時間 | 培養基名稱 | 原始數據 | | | |
| 大腸桿菌群 | CFU/100 mL | <1 | 114年11月04日 11時30分 | LES Endo Agar | 1倍/0，0 | NIEA E230.55B | 6 | |
| 以下空白 | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

PASS



檢驗室地址：桃園市中壢區遠東路 128 號 聯絡人：陳秀雲
電話：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

# Environmental Technology Research Center
# YUAN ZE UNIVERSITY
## Analysis Report

**Client:** Yuann International Technology Co., Ltd
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
**Plant:** Golden –Brother International Co., Ltd.
**IndustrialType:** ---
**Sampling Site:** Zhongli Wenhua 2nd building H1/1F water dispenser

**Client Number:** YZ1141C4753
**Sample Base:** Drinking Water
**Test purpose:** **Regular inspection**
**Sampling Date:** 11/03/2025 15:40
**Sample Received:** 11/04/2025

**Sampling Organization:** Yuann International Technology Co., Ltd
**Sampling Method:** ---
**Sampling Code:** ---

**Report Date:** 11/17/2025
**Report Number:** C1144753-1

| Sample Report Number | | C1141104K | | | | Analytical Method | Drinking water standard of MOENV | Remarks |
|---|---|---|---|---|---|---|---|---|
| Sample Name(Number) | | Drinking Water | | | | | | |
| Analyzed Item | Unit | Analytical Value | Start Time of Incubating | Medium | Original Data | | | |
| Coliform Group | CFU/100 mL | <1 | 11/04/2025 11:30 | LES Endo Agar | 1/0，0 | NIEA E230.55B | 6 | |
| The END | | | | | | | | |

PASS



Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887