國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
委託者地址：桃園市平鎮區中豐路南勢二段 127 號
受檢單位：鎵興國際股份有限公司
行業別：自述業別
採樣地點：中壢自強三館 C05/4F 飲水機 (桃園市中壢區)
採樣單位：御安淨水企業有限公司
採樣方法：---
採樣行程代碼：---

委託編號：YZ1141C4750
樣品基質：飲用水
檢測目的：定檢
採樣時間：114年11月03日15時00分
收樣時間：114年11月04日
報告日期：114年11月17日
報告編號：C1144750-1

樣品報告編號		C1141104H				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年11月04日 11時30分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號 聯絡人：陳秀雲
電話：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden –Brother International Co., Ltd.
IndustrialType: ---
Sampling Site: Zhongli Ziqiang 3rd building C05/4F water dispenser

Client Number: YZ1141C4750
Sample Base: Drinking Water
Test purpose: **Regular inspection**
Sampling Date: 11/03/2025 15:00
Sample Received: 11/04/2025

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 11/17/2025
Report Number: C1144750-1

Sample Report Number		C1141104H				Analytical Method	Drinking water standard of MOENV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/04/2025 11:30	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887