

















# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：家興人力資源顧問股份有限公司  
 行業別：自述業別  
 採樣地點：高雄大學館 H08/A 棟 10F  
 (高雄市楠梓區 )  
 採樣單位：家興人力資源顧問股份有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號： YZ1141C5299  
 樣品基質： 飲用水  
 檢測目的： 定期檢測  
 採樣時間： 114年12月11日15時05分  
 收樣時間： 114年12月12日  
 報告日期： 114年12月22日  
 報告編號： C1145299-8

樣品報告編號		C1141212M				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年12月12日 10時55分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS





# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1141C5299
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定期檢測
行業別：自述業別	採樣時間：114年12月11日15時15分
採樣地點：高雄大學館 H10/12F 飲水機 (高雄市楠梓區)	收樣時間：114年12月12日
採樣單位：家興人力資源顧問股份有限公司	報告日期：114年12月22日
採樣方法：---	報告編號：C1145299-10
採樣行程代碼：---	

樣品報告編號		C11412120				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年12月12日 10時55分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：家興人力資源顧問股份有限公司  
 行業別：自述業別  
 採樣地點：高雄大學館 H11/12F 飲水機  
 (高雄市楠梓區)  
 採樣單位：家興人力資源顧問股份有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1141C5299  
 樣品基質：飲用水  
 檢測目的：定期檢測  
 採樣時間：114年12月11日15時20分  
 收樣時間：114年12月12日  
 報告日期：114年12月22日  
 報告編號：C1145299-11

樣品報告編號		C1141212P				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年12月12日 10時55分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS





# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1141C5299
委託者地址：桃園市平鎮區中豐路南勢二段127號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定期檢測
行業別：自述業別	採樣時間：114年12月11日14時40分
採樣地點：高雄大學館336號H03/4F (高雄市楠梓區 )	收樣時間：114年12月12日
採樣單位：家興人力資源顧問股份有限公司	報告日期：114年12月22日
採樣方法：---	報告編號：C1145299-14
採樣行程代碼：---	

樣品報告編號		C1141212H				檢驗方法	環境部 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	114年12月12日 10時55分	TGE Agar	1倍/0.0	NIEA E203.56B	100	
以下空白								

PASS



















Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center  
 YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung University dormitory No.338 H01/ 10F

**Client Number:** YZ1141C5299  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 12/11/2025 14:30  
**Sample Received:** 12/12/2025

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 12/22/2025  
**Report Number:** C1145299-1

Sample Report Number		C1141212F				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	12/12/2025 10:55	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center  
 YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung University dormitory No.338 H02/ 4F

**Client Number:** YZ1141C5299  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 12/11/2025 14:35  
**Sample Received:** 12/12/2025

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 12/22/2025  
**Report Number:** C1145299-2

Sample Report Number		C1141212G				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	12/12/2025 10:55	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**



















# Environmental Technology Research Center

## YUAN ZE UNIVERSITY

### Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung University dormitory No.338 H01/ 10F

**Client Number:** YZ1141C5299  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 12/11/2025 14:30  
**Sample Received:** 12/12/2025

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 12/22/2025  
**Report Number:** C1145299-12

Sample Report Number		C1141212F				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	12/12/2025 10:55	TGE Agar	1/0 , 0	NIEA E203.56B	100	
<b>The END</b>								

PASS

Environmental Technology Research Center  
YUAN ZE UNIVERSITY

Analysis Report

**Client:** Yuann International Technology Co., Ltd

**Client Number:** YZ1141C5299

**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

**Sample Base:** Drinking Water

**Plant:** Golden Li H.R Consultant Co., Ltd

**Test purpose:** Regular inspection

**IndustrialType:** ---

**Sampling Date:** 12/11/2025 14:35

**Sampling Site:** Kaohsiung University dormitory No.338 H02/ 4F

**Sample Received:** 12/12/2025

**Sampling Organization:** Yuann International Technology Co., Ltd

**Report Date:** 12/22/2025

**Sampling Method:** ---

**Report Number:** C1145299-13

**Sampling Code:** ---

Sample Report Number		C1141212G				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	12/12/2025 10:55	TGE Agar	1/0 · 0	NIEA E203.56B	100	
<b>The END</b>								

PASS

# Environmental Technology Research Center

## YUAN ZE UNIVERSITY

### Analysis Report

**Client:** Yuann International Technology Co., Ltd

**Client Number:** YZ1141C5299

**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

**Sample Base:** Drinking Water

**Plant:** Golden Li H.R Consultant Co., Ltd

**Test purpose:** Regular inspection

**IndustrialType:** ---

**Sampling Date:** 12/11/2025 14:40

**Sampling Site:** Kaohsiung University dormitory No.336 H03/ 4F

**Sample Received:** 12/12/2025

**Sampling Organization:** Yuann International Technology Co., Ltd

**Report Date:** 12/22/2025

**Sampling Method:** ---

**Report Number:** C1145299-14

**Sampling Code:** ---

Sample Report Number		C1141212H				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	12/12/2025 10:55	TGE Agar	1/0 · 0	NIEA E203.56B	100	
<b>The END</b>								

PASS

Environmental Technology Research Center  
YUAN ZE UNIVERSITY

Analysis Report

**Client:** Yuann International Technology Co., Ltd

**Client Number:** YZ1141C5299

**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

**Sample Base:** Drinking Water

**Plant:** Golden Li H.R Consultant Co., Ltd

**Test purpose:** Regular inspection

**IndustrialType:** ---

**Sampling Date:** 12/11/2025 14:45

**Sampling Site:** Kaohsiung University dormitory No.338 H04/ 1F

**Sample Received:** 12/12/2025

**Sampling Organization:** Yuann International Technology Co., Ltd

**Report Date:** 12/22/2025

**Sampling Method:** ---

**Report Number:** C1145299-15

**Sampling Code:** ---

Sample Report Number		C1141212I				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	12/12/2025 10:55	TGE Agar	1/0 · 0	NIEA E203.56B	100	
<b>The END</b>								

PASS



Environmental Technology Research Center  
YUAN ZE UNIVERSITY

Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung University dormitory H06/ Building B 7F

**Client Number:** YZ1141C5299  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 12/11/2025 14:55  
**Sample Received:** 12/12/2025

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 12/22/2025  
**Report Number:** C1145299-17

Sample Report Number		C1141212K				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	12/12/2025 10:55	TGE Agar	1/0 · 0	NIEA E203.56B	100	
<b>The END</b>								

# Environmental Technology Research Center

## YUAN ZE UNIVERSITY

### Analysis Report

**Client:** Yuann International Technology Co., Ltd

**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

**Plant:** Golden Li H.R Consultant Co., Ltd

**IndustrialType:** ---

**Sampling Site:** Kaohsiung University dormitory H07 /Building A 7F

**Client Number:** YZ1141C5299

**Sample Base:** Drinking Water

**Test purpose:** Regular inspection

**Sampling Date:** 12/11/2025 15:00

**Sample Received:** 12/12/2025

**Sampling Organization:** Yuann International Technology Co., Ltd

**Sampling Method:** ---

**Sampling Code:** ---

**Report Date:** 12/22/2025

**Report Number:** C1145299-18

Sample Report Number		C1141212L				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	12/12/2025 10:55	TGE Agar	1/0 , 0	NIEA E203.56B	100	
<b>The END</b>								

PASS



# Environmental Technology Research Center

## YUAN ZE UNIVERSITY

### Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung University dormitory H09/ 1F water dispenser

**Client Number:** YZ1141C5299  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 12/11/2025 15:10  
**Sample Received:** 12/12/2025

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 12/22/2025  
**Report Number:** C1145299-20

Sample Report Number		C1141212N				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	12/12/2025 10:55	TGE Agar	1/0 , 0	NIEA E203.56B	100	
<b>The END</b>								





