



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1151C0580
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定期檢測
行業別：自選業別	採樣時間：115年02月02日 13時45分
採樣地點：高雄大學館 338 號 H04/1F (高雄市楠梓區)	收樣時間：115年02月03日
採樣單位：家興人力資源顧問股份有限公司	報告日期：115年02月10日
採樣方法：---	報告編號：C1150580-4
採樣行程代碼：---	

樣品報告編號		C1150203K				檢驗方法	環境部 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年02月03日 11時30分	LES Endo Agar	1#0.0	NIEA E230.55B	6	
以下空白								
PASS								



元智大學環科中心檢測實驗室 樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1151C0580
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司	檢測目的：定期檢測
行業別：自述業別	採樣時間：115年02月02日 13時50分
採樣地點：高雄大學館 338 號 H05/1F (高雄市楠梓區)	收樣時間：115年02月03日
採樣單位：家興人力資源顧問股份有限公司	報告日期：115年02月10日
採樣方法：---	報告編號：C1150580-5
採樣行程代碼：---	

樣品報告編號		C1150203L				檢驗方法	環境部 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年02月03日 11時30分	LES Endo Agar	1.00/0.0	NIEA E230.55B	6	
以下空白								

PASS

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li HR Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H02/ 4F

Client Number: YZ1151C0580
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 02/02/2026 13:35
Sample Received: 02/03/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 02/10/2026
Report Number: C1150580-13

Sample Report Number		C11502031				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	02/03/2026 11:30	TGE Agar	1/0 * 0	NIEA E203.56B	100	
The END								

Environmental Technology Research Center

YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H07 /Building A 7F

Client Number: YZ1151C0580
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 02/02/2026 14:00
Sample Received: 02/03/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 02/10/2026
Report Number: C1150580-18

Sample Report Number		C1150203N				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	02/03/2026 11:30	TGE Agar	1/0 * 0	NIEA E203.56B	100	
The END								

PASS

Environmental Technology Research Center

YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H11/ 12F water dispenser

Client Number: YZ1151C0580
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 02/02/2026 14:20
Sample Received: 02/03/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 02/10/2026
Report Number: C1150580-22

Sample Report Number		C1150203R				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	02/03/2026 11:30	TGE Agar	1/0 + 0	NIEA E203.56B	100	
The END								

PASS