元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C1472
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：鎵興國際股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年04月01日09時10分
採樣地點：中壢中華六館 1F 飲水機(桃園市中壢區)　　收樣時間：115年04月01日
採樣單位：御安淨水企業有限公司　　報告日期：115年04月09日
採樣方法：---　　報告編號：C1151472-1
採樣行程代碼：---

樣品報告編號		C1150401F				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年04月01日19時00分	LES Endo Agar	1倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C1472
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：鎵興國際股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年04月01日09時20分
採樣地點：中壢中華六館 3F 飲水機(桃園市中壢區)　　收樣時間：115年04月01日
採樣單位：御安淨水企業有限公司　　報告日期：115年04月09日
採樣方法：---　　報告編號：C1151472-2
採樣行程代碼：---

樣品報告編號		C1150401G				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年04月01日19時00分	LES Endo Agar	1倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden –Brother International Co., Ltd.
IndustrialType: ---
Sampling Site: Zhongli Zhonghua 6nd building,1F water dispenser

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1151C1472
Sample Base: Drinking Water
Test purpose: **Regular inspection**
Sampling Date: 04/01/3026 09:10
Sample Received: 04/01/3026
Report Date: 04/08/3026
Report Number: C1151472-1

Sample Report Number		C1150401F				Analytical Method	Drinking water standard of MOENV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	04/01/3026 19:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client:	Yuann International Technology Co., Ltd	**Client Number:**	YZ1151C1472
Address:	No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)	**Sample Base:**	Drinking Water
Plant:	Golden –Brother International Co., Ltd.	**Test purpose:**	**Regular inspection**
IndustrialType:	---	**Sampling Date:**	04/01/3026 09:20
Sampling Site:	Zhongli Zhonghua 6nd building,3F water dispenser	**Sample Received:**	04/01/3026
Sampling Organization:	Yuann International Technology Co., Ltd	**Report Date:**	04/08/3026
Sampling Method:	---	**Report Number:**	C1151472-2
Sampling Code:	---		

Sample Report Number		C1150401G				Analytical Method	Drinking water standard of MOENV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	04/01/3026 19:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887