



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：錄興國際股份有限公司
 行業別：自述業別
 採樣地點：中壢成章一館 2F 飲水機
 (桃園市中壢區)

委託編號：YZ1151C2091
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：115年05月04日15時30分
 收樣時間：115年05月05日

採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

報告日期：115年05月13日
 報告編號：C1152091-1

樣品報告編號		C11503060				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年05月05日 11時00分	LES Endo Agar	1倍/0.0	NIEA E230.55B	6	
以下空白								



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Brother International Co., Ltd.
IndustrialType: ---
Sampling Site: Zhongli Chengzhang Hall 1 2F Water Dispenser

Client Number: YZ1151C2091
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 05/04/2026 15:30
Sample Received: 05/05/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 05/13/2026
Report Number: C1152091-1

Sample Report Number		C11505050				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	05/05/2026 11:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								

PASS