



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：宏普人力資源股份有限公司
 行業別：自述業別
 採樣地點：湖口安宅一館 D1 飲水機
 (新竹縣湖口鄉)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1151C2613
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：115年06月08日14時00分
 收樣時間：115年06月09日
 報告日期：115年06月16日
 報告編號：C1152613-1

樣品報告編號		C1150609C				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年06月09日 12時00分	LES Endo Agar	1倍/0,0	NIEA E230.55B	6	
以下空白								

PASS



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd **Client Number:** YZ1151C2613
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., **Sample Base:** Drinking Water
 Pingzhen City, Taoyuan County, Taiwan
 (R.O.C.)
Plant: Summit Manpower Agency Co,Ltd **Test purpose:** Regular inspection
Industrial Type: --- **Sampling Date:** 06/08/2026 14:00
Sampling Site: D1 water dispenser, Hukou Anzhai Building 1 **Sample Received:** 06/09/2026

Sampling Organization: Yuann International **Report Date:** 06/16/2026
 Technology Co., Ltd
Sampling Method: --- **Report Number:** C1152613-1
Sampling Code: ---

Sample Report Number		C1150609C				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/09/2026 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
以下空白								

PASS