國環檢證字號：041(原環署環檢字第 041 號)

# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委 託 單 位 ：御安淨水企業有限公司　　委 託 編 號 ：YZ1151C4251
委 託 者 地 址 ：桃園市平鎮區中豐路南勢二段 127 號　樣 品 基 質 ：飲用水
受 檢 單 位 ：家興人力資源顧問股份有限公司　檢 測 目 的 ：定檢
行 業 別 ：自述業別　　採 樣 時 間 ：115年09月09日15時00分
採 樣 地 點 ：湖口興華一館 D2 飲水機　　收 樣 時 間 ：115年09月10日
(新竹縣湖口鄉　　)
採 樣 單 位 ：御安淨水企業有限公司　　報 告 日 期 ：115年09月22日
採 樣 方 法 ：---　　報 告 編 號 ：C1154251-1
採樣行程代碼：---

| 樣品報告編號 | | C1150910D | | | | 檢驗方法 | 環境部飲用水標準值 | 備註欄 |
|---|---|---|---|---|---|---|---|---|
| 原樣名稱或編號 | | 飲用水 | | | | | | |
| 檢測項目 | 單位 | 檢測值 | 開始培養時間 | 培養基名稱 | 原始數據 | | | |
| 大腸桿菌群 | CFU/100 mL | <1 | 115年09月10日 12時00分 | LES Endo Agar | 1 倍/0，0 | NIEA E230.55B | 6 | |
| 以下空白 | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

PASS



檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

# Environmental Technology Research Center
# YUAN ZE UNIVERSITY
## Analysis Report

**Client:** Yuann International Technology Co., Ltd
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
**Plant:** Golden Li H.R Consultant Co., Ltd
**IndustrialType:** ---
**Sampling Site:** Hukou Xinghua Hall 1 D2 drinking fountain

**Client Number:** YZ1151C4251
**Sample Base:** Drinking Water
**Test purpose:** **Regular inspection**
**Sampling Date:** 09/09/2026 15:00
**Sample Received:** 09/10/2026

**Sampling Organization:** Yuann International Technology Co., Ltd
**Sampling Method:** ---
**Sampling Code:** ---

**Report Date:** 09/22/2026
**Report Number:** C1154251-1

| Sample Report Number | | C1150910D | | | | Analytical Method | Drinking water standard of MOENV | Remarks |
|---|---|---|---|---|---|---|---|---|
| Sample Name(Number) | | Drinking Water | | | | | | |
| Analyzed Item | Unit | Analytical Value | Start Time of Incubating | Medium | Original Data | | | |
| Coliform Group | CFU/100 mL | <1 | 09/10/2026 12:00 | LES Endo Agar | 1/0，0 | NIEA E230.55B | 6 | |
| **The END** | | | | | | | | |

PASS

P2/2

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887