元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C4436
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年09月21日13時00分
採樣地點：安南科工一館 A 棟 3F/A6 飲水機(台南市安南區)　　收樣時間：115年09月22日
採樣單位：御安淨水企業有限公司　　報告日期：115年10月02日
採樣方法：---　　報告編號：C1154436-1
採樣行程代碼：---

樣品報告編號		C1150922A				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年09月22日 10時30分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C4436
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年09月21日13時30分
採樣地點：安南科工一館 B 棟 2F/B4 飲水機(台南市安南區)　　收樣時間：115年09月22日
採樣單位：御安淨水企業有限公司　　報告日期：115年10月02日
採樣方法：---　　報告編號：C1154436-2
採樣行程代碼：---

樣品報告編號		C1150922B				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年09月22日 10時30分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C4436
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年09月21日14時00分
採樣地點：安南科工一館 C 棟 3F/C4 飲水機(台南市安南區)　　收樣時間：115年09月22日
採樣單位：御安淨水企業有限公司　　報告日期：115年10月02日
採樣方法：---　　報告編號：C1154436-3
採樣行程代碼：---

樣品報告編號		C1150922C				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年09月22日 10時30分	LES Endo Agar	1倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C4436
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年09月21日14時00分
採樣地點：安南科工一館 D 棟 3F/D4 飲水機(台南市安南區)　　收樣時間：115年09月22日
採樣單位：御安淨水企業有限公司　　報告日期：115年10月02日
採樣方法：---　　報告編號：C1154436-4
採樣行程代碼：---

樣品報告編號		C1150922D				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年09月22日 10時30分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C4436
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年09月21日13時00分
採樣地點：安南科工一館A棟3F/A6飲水機(台南市安南區)　　收樣時間：115年09月22日
採樣單位：御安淨水企業有限公司　　報告日期：115年10月02日
採樣方法：---　　報告編號：C1154436-5
採樣行程代碼：---

樣品報告編號		C1150922A				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	115年09月22日 10時30分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

第2頁共5頁

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C4436
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年09月21日13時30分
採樣地點：安南科工一館B棟2F/B4飲水機(台南市安南區)　　收樣時間：115年09月22日
採樣單位：御安淨水企業有限公司　　報告日期：115年10月02日
採樣方法：---　　報告編號：C1154436-6
採樣行程代碼：---

樣品報告編號		C1150922B				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	115年09月22日 10時30分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C4436
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年09月21日14時00分
採樣地點：安南科工一館C棟3F/C4飲水機(台南市安南區)　　收樣時間：115年09月22日
採樣單位：御安淨水企業有限公司　　報告日期：115年10月02日
採樣方法：---　　報告編號：C1154436-7
採樣行程代碼：---

樣品報告編號		C1150922C				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	115年09月22日 10時30分	TGE Agar	1倍/0，0	NIEA E203.56B	100	
以下空白								

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C4436
委託者地址：桃園市平鎮區中豐路南勢二段127號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年09月21日14時00分
採樣地點：安南科工一館D棟3F/D4飲水機(台南市安南區)　　收樣時間：115年09月22日
採樣單位：御安淨水企業有限公司　　報告日期：115年10月02日
採樣方法：---　　報告編號：C1154436-8
採樣行程代碼：---

樣品報告編號		C1150922D				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	63	115年09月22日 10時30分	TGE Agar	1倍/12，13	NIEA E203.56B	100	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路128號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Annan Kegong Hall 1 Building A 3F/A6

Client Number: YZ1151C4436
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 09/21/2026 13:00
Sample Received: 09/22/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 10/02/2026
Report Number: C1154436-1

Sample Report Number		C1150922A				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	09/22/2026 10:30	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Annan Kegong Hall 1 Building B 2F/B4

Client Number: YZ1151C4436
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 09/21/2026 13:30
Sample Received: 09/22/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 10/02/2026
Report Number: C1154436-2

Sample Report Number		C1150922B				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	09/22/2026 10:30	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Annan Kegong Hall 1 Building C 3F/C4

Client Number: YZ1151C4436
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 09/21/2026 14:00
Sample Received: 09/22/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 10/02/2026
Report Number: C1154436-3

Sample Report Number		C1150922C				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	09/22/2026 10:30	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Annan Kegong Hall 1 Building D 3F/D4

Client Number: YZ1151C4436
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 09/21/2026 14:00
Sample Received: 09/22/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 10/02/2026
Report Number: C1154436-4

Sample Report Number		C1150922D				Analytical Method	Drinking water standard of MoEnV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	09/22/2026 10:30	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Annan Kegong Hall 1 Building A 3F/A6

Client Number: YZ1151C4436
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 09/21/2026 13:00
Sample Received: 09/22/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 10/02/2026
Report Number: C1154436-5

Sample Report Number		C1150922A				Analytical Method	Drinking water standard of MOENV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	09/22/2026 10:30	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Annan Kegong Hall 1 Building B 2F/B4

Client Number: YZ1151C4436
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 09/21/2026 13:30
Sample Received: 09/22/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 10/02/2026
Report Number: C1154436-6

Sample Report Number		C1150922B				Analytical Method	Drinking water standard of MOENV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	09/22/2026 10:30	TGE Agar	1/0 · 0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Annan Kegong Hall 1 Building C 3F/C4

Client Number: YZ1151C4436
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 09/21/2026 14:00
Sample Received: 09/22/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 10/02/2026
Report Number: C1154436-7

Sample Report Number		C1150922C				Analytical Method	Drinking water standard of MOENV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	09/22/2026 10:30	TGE Agar	1/0，0	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Annan Kegong Hall 1 Building D 3F/D4

Client Number: YZ1151C4436
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 09/21/2026 14:00
Sample Received: 09/22/2026

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 10/02/2026
Report Number: C1154436-8

Sample Report Number		C1150922D				Analytical Method	Drinking water standard of MOENV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	63	09/22/2026 10:30	TGE Agar	1/12，13	NIEA E203.56B	100	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887