元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1151C4359
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：115年09月15日15時20分
採樣地點：中壢文林一館 5F 右邊飲水機 (桃園市中壢區)　　收樣時間：115年09月16日
採樣單位：御安淨水企業有限公司　　報告日期：115年09月23日
採樣方法：---　　報告編號：C1154359-1
採樣行程代碼：---

樣品報告編號		C1150916A				檢驗方法	環境部飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	115年09月16日 12時00分	LES Endo Agar	1倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client:	Yuann International Technology Co., Ltd	**Client Number:**	YZ1151C4359
Address:	No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)	**Sample Base:**	Drinking Water
Plant:	Golden Li H.R Consultant Co., Ltd	**Test purpose:**	Regular inspection
IndustrialType:	---	**Sampling Date:**	09/15/2026 15:20
Sampling Site:	Zhongli Wenli Hall 1 5F, Right Side Water dispenser	**Sample Received:**	09/16/2026
Sampling Organization:	Yuann International Technology Co., Ltd	**Report Date:**	09/23/2026
Sampling Method:	---	**Report Number:**	C1154359-1
Sampling Code:	---		

Sample Report Number		C1150916A				Analytical Method	Drinking water standard of MOENV	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	09/16/2026 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

P2/2

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887